

Prüfbericht-Nr.: Test Report No.:	50163017 001	Auftrags-Nr.: Order No.:	1140035154	Seite 1 von 21 Page 1 of 21
Kunden-Referenz-Nr.: Client Reference No.:	442296	Auftragsdatum: Order date:	18.05.2017	
Auftraggeber: Client:	Changzhou Fengguo Jin'e Cable Co., Ltd. Changzhou Furong Industrial Park, Changzhou, Jiangsu, P. R. China	Henshan Bridge Town,Wujin District,		
Prüfgegenstand: Test item:	Electric Cables for Photovoltaic Systems			
Bezeichnung / Typ-Nr.: Identification / Type No.:	H1Z2Z2-K 1X2,5...6mm2			
Auftrags-Inhalt: Order content:	TÜV mark approval			
Prüfgrundlage: Test specification:	EN 50618:2014 Kabel und Leitungen - Leitungen für Photovoltaic Systeme Electric cables for photovoltaik systems			
Wareneingangsdatum: Date of receipt:	22.05.2017			
Prüfmuster-Nr.: Test sample No.:	Engineering sample			
Prüfzeitraum: Testing period:	19.06.2017 - 09.05.2018			
Ort der Prüfung: Place of testing:	See Other below for details			
Prüflaboratorium: Testing laboratory:	TÜV Rheinland (China) Ltd.			
Prüfergebnis*: Test result*:	Pass			
geprüft von / tested by:	Vivian Ren / PE	kontrolliert von / reviewed by:  2018-07-09 Liu Bo / TC Datum Date Name / Stellung Name / Position Unterschrift Signature		
Sonstiges / Other: Place of testing:	National Quality Supervision and Testing Center for Cables and Wires (Jiangsu) 500 Lvyan Road, Yixing, China	 2018-07-11 Datum Date Name / Stellung Name / Position Unterschrift Signature		
Zustand des Prüfgegenstandes bei Anlieferung: Condition of the test item at delivery:	Prüfmuster vollständig und unbeschädigt Test item complete and undamaged			
* Legende: P(ass) = entspricht o.g. Prüfgrundlage(n)	1 = sehr gut 2 = gut 3 = befriedigend	F(all) = entspricht nicht o.g. Prüfgrundlage(n)	4 = ausreichend N/A = nicht anwendbar	5 = mangelhaft N/T = nicht getestet
Legend: P(ass) = passed a.m. test specification(s)	1 = very good 2 = good 3 = satisfactory	F(all) = failed a.m. test specification(s)	4 = sufficient N/A = not applicable	5 = poor N/T = not tested
<p style="text-align: center;">Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens.</p> <p style="text-align: center;"><i>This test report only relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark.</i></p>				

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 2 von 21
Page 2 of 21

Liste der verwendeten Prüfmittel
List of used test equipment

Prüfmittel <i>Test equipment</i>	Prüfmittel-Nr. / ID-Nr. <i>Equipment No. / ID-No.</i>	Nächste Kalibrierung <i>Next calibration</i>
See attachment 1		
Following blank		

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 3 von 21
Page 3 of 21

Produktbeschreibung
Product description

Characteristics of cable										
Code designation	H1Z2Z2-K									
Trademark	Changzhou Fengguo Jin'e Cable Co., Ltd.									
Rated Voltage AC	U ₀ /U AC: 1/1 kV									
Rated voltage DC	1,5 kV DC (conductor-conductor and conductor-earth)									
Cross section: [mm ²]	2,5	4	6							
Outer dimension: [mm]	5,6	6,6	7,0							
Meas. wall thickness insulation: [mm]	0,9	0,7	1,1							
Specified value of thickness insulation: [mm]	0,7	0,7	0,7							
Meas. wall thickness sheath: [mm]	1,0	0,8	0,9							
Specified value of thickness sheath: [mm]	0,8	0,8	0,8							
Min. wall thickness compl. Insulation: [mm]	-	-	-							
Standard	EN 50618:2014									
Lower ambient temperature	-40 °C									
Upper ambient temperature	+90 °C									
Max temperature at conductor	+120°C @ 20.000 h (see enclosed Arrhenius curve)									
Material separation layer between conductor and insulation	—									
Material insulation	Halogen free cross-linked polyolefin MG80027J (EN) - 125									
Material separation layer between insulation and sheath	—									
Material sheath	Halogen free cross-linked polyolefin MG80027H (EN) - 125									
Extrusion type	Tandem Extrusion									
Remarks:										
All tests according to EN 50618:2014 in this report were performed to the complete cable H1Z2Z2-K 1X2.5mm ² with 300m.										
All tests except Ref. No. 1.4 in Table B.1 were performed to the complete cable H1Z2Z2-K 1X6mm ² with 100m.										
Test of Ref. No. 15 in Table 2 was performed to the complete cable H1Z2Z2-K 1X4mm ² with 30m.										
This test report contains 21 pages and an attachment 1 with 2 pages for testing equipment list.										

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 4 von 21
Page 4 of 21

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation

5.1	CONDUCTOR		
5.1.1	Material		
	Number of cores:	1	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	Single wires are of copper and tinned:	tinned copper wire	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	Compliance with class 5 acc. to IEC 60228 <i>SEE TABLE 5.1.5</i>	class 5 conductors	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	There are no visible gaps in the continuous layer, when examined with normal or corrected vision.	no visible gaps	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
5.1.2	CONSTRUCTION		
	The class of the conductor must be class 5 in accordance to EN 60228		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	The maximum diameter of the wires in the conductor are be in accordance to EN 60228		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
5.1.3	SEPERATOR BETWEEN CONDUCTOR AND INSULATION		
	Separation layer of halogen free material between insulation and conductor		P <input type="checkbox"/> F <input type="checkbox"/> N/A <input checked="" type="checkbox"/> N/T <input type="checkbox"/>
5.1.4	CHECK OF CONSTRUCTION		
	The construction must be checked in accordance of the requirements of 5.1.1, 5.1.2 and 5.1.3 including the requirements of EN 60228 for class 5 conductor	checked	
5.1.5	ELECTRICAL RESISTANCE		

Prüfbericht-Nr.: 50163017 001 Test Report No.:			Seite 5 von 21 Page 5 of 21	
Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung	
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation	
	The resistor of each conductor at 20°C must be in accordance with the requirements of EN 60228 for class 5 conductor		P <input checked="" type="checkbox"/>	
	Compliance must be checked by the test of clause 5 of EN 50395		F <input type="checkbox"/>	
			N/A <input type="checkbox"/>	
			N/T <input type="checkbox"/>	
5.2	INSULATION			
5.2.1	MATERIAL			
	The insulation must be crosslinked and fulfil the requirements of table B.1 in Annex B	Halogen free cross-linked polyolefin in black	P <input checked="" type="checkbox"/>	
			F <input type="checkbox"/>	
			N/A <input type="checkbox"/>	
			N/T <input type="checkbox"/>	
5.2.2	APPLICATION TO THE CONDUCTOR			
	Insulation extruded, smooth and consistently applied and possible to remove without damage to the insulation itself, to the conductor or to the tin coating.		P <input checked="" type="checkbox"/>	
			F <input type="checkbox"/>	
			N/A <input type="checkbox"/>	
			N/T <input type="checkbox"/>	
5.2.3	THICKNESS			
	For each piece of insulation, the average of the measured values, rounded to 0,1 mm have be not less than the specified value for each size of table 1		P <input checked="" type="checkbox"/>	
			F <input type="checkbox"/>	
			N/A <input type="checkbox"/>	
			N/T <input type="checkbox"/>	
	The smallest value must not fall below 90% of the specified value by more than 0,1 mm. Compliance must be checked using by test of clause 4.1 of EN 50396		P <input checked="" type="checkbox"/>	
			F <input type="checkbox"/>	
			N/A <input type="checkbox"/>	
			N/T <input type="checkbox"/>	
5.3	SHEATH			
	The sheath must be crosslinked and fulfil the requirements of table B.1 in Annex B	Halogen free cross-linked polyolefin in black	P <input checked="" type="checkbox"/>	
			F <input type="checkbox"/>	
			N/A <input type="checkbox"/>	
			N/T <input type="checkbox"/>	

Prüfbericht-Nr.: 50163017 001	Seite 6 von 21 Page 6 of 21
Test Report No.:	

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation

5.3.2 APPLICATION			
	The sheath must be applied homogeneously by extrusion and halogen free material. The application of the sheath must give the finished cable a practically circular shape		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	Separation layer of halogen free material between insulation and sheath		P <input type="checkbox"/> F <input type="checkbox"/> N/A <input checked="" type="checkbox"/> N/T <input type="checkbox"/>
5.3.3 THICKNESS			
	For each piece of insulation, the average of the measured values, rounded to 0,1 mm must be less than the specified value for each size of table 1		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	The smallest value must not fall below 85% of the specified value by more than 0,1 mm. Compliance must be checked using by test of clause 4.1 of EN 50396		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
5.3.4 COLOUR			
	The colour of the sheath must be black, unless otherwise agreed between manufacturer and customer. The colour must be throughout for whole sheath.	black sheath	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
6 MARKING			
6.1 GENERAL			
	The marking at the sheath must be by printing, embossing or indenting.	by printing	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
6.2 INDICATION OF ORIGIN			
Cables are marked with			
a) manufacturer's name or Trademark or identification number	Changzhou Fengguo Jin'e Cable Co., Ltd.		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 7 von 21
Page 7 of 21

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation
6.3	b) Code designation	H1Z2Z2-K	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
6.4	c) Nominal cross-sectional area of conductor	2,5...6mm ²	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
6.5	CONTINUITY OF MARKING		
	Spacing between the end of marking and the begin of the following identical marking does not exceed 550mm	=<550mm	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
6.6	The name CENELEC, in full or abbreviated, does not be marked on, or in, the cables		P <input type="checkbox"/> F <input type="checkbox"/> N/A <input checked="" type="checkbox"/> N/T <input type="checkbox"/>
6.7.1	Marking is still legible after test of cl. 5.1 of EN 50396		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
6.7.2	All markings are legible.		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
Table 2	TEST FOR CABLES TO EN 50618		
1	ELECTRICAL TEST		
1.1.1	Conductor resistance <i>SEE CLAUSE 5.1.5 AND TABLE 5.1.5</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.2	No breakdown at high voltage test with		
	- AC 6,5kV, or	no breakdown	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	- DC 15kV		P <input type="checkbox"/> F <input type="checkbox"/> N/A <input checked="" type="checkbox"/> N/T <input type="checkbox"/>

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 8 von 21
Page 8 of 21

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation

1.4	Insulation resistance		
1.4.1.2	- during test in water at 20°C Min. as stated in table 1 of this standard: [MOhm*km] <i>see table 8.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.4.2	- during test in water at 90°C Min. as stated in table 1 of this standard: [MOhm*km] <i>see table 8.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.5.1	During long term resistance of insulation to D.C. a stable progress has been identified, no breakdown of the test voltage: [V d.c.]	no breakdown	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.5.2	After long term resistance test no damage or cracks of the insulation have been visible.	no damage and visible cracks	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.6.2	Surface resistance of sheath min 10 GOhm: [Ohm]	1X2,5: 1X10 ⁹ Ω 1X6: 1,2X10 ¹¹ Ω	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
2	CONSTRUCTIONAL AND DIMENSIONAL TEST		
2.1	Conductor Maximum diameter of the conductor in accordance to EN 60228 clause 6.1 <i>SEE table 5.1.5</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
2.1.2			
2.2	Checking continuity of tin to clause 5.1.1 No visible gaps occurred	no visible gaps	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
2.3	Wall thickness of insulation Not less than stated in clause 5.2.3 of this standard <i>SEE TABLE 5.2.3</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	Wall thickness of sheath Not less than stated in clause 5.3.3 of this standard <i>SEE TABLE 5.3.3</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	Measurement of overall dimensions Not less than stated in table 1 of this standard <i>SEE TABLE 5.3.4</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 9 von 21
Page 9 of 21

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation
	Mean value <i>SEE TABLE 7.3.3</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
2.4	Ovality max. 15% Not less than stated in clause 7.3.3 of this standard <i>SEE TABLE 7.3.3</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
2.5 2.5.1	Sheath colour Visual examination as stated in clause 7.3.1 of this standard	black	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
2.6 2.6.1	Sheath marking Visual examination and measurement as stated in clause 7.3.2 of this standard		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
3	Insulation material as stated in table B.1 of this standard		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
4	Sheath material as stated in table B.1 of this standard		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
5	COMPATIBILITY TEST ACCORDING TO EN 60811-401		
5.1	Test conditions: Duration of test Temperature	168 h 135 ± 2 °C	
5.2	Result in accordance to Table B.1 Lfd. No.: 1.7 of this standard <i>SEE RESULT OF TABLE B1 NO. 1.7</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
6	COLD IMPACT TEST ACCORDING TO EN 60811-506		
6.1	Test conditions as stated in annex C of this standard -40°C	-40° C, 16h mass of hammer: 1000g height: 100mm	
6.2	After the test no cracks are visible	no visible cracks	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
7	COLD BENDING TEST ACCORDING TO EN 60811-504 (Cable diameter ≤ 12,5 mm)		

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 10 von 21
Page 10 of 21

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation
7.1	Test conditions: Conditioning duration 16 h: Temperature -40 ± 2°C: Diameter of mandrel: [mm]	-40°C, 16h diameter of mandrel: 1X2,5: 25,7mm 1X6: 32,0mm	
7.2	After the test no cracks are visible	no visible cracks	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
8	COLD ELONGATION TEST ACCORDING TO EN 60811-505 (Cable diameter > 12,5 mm)		
8.1	Test conditions: Conditioning duration 16 h Temperature -40 ± 2°C		
	Elongation at break min 30%: [%]		P <input type="checkbox"/> F <input type="checkbox"/> N/A <input checked="" type="checkbox"/> N/T <input type="checkbox"/>
9	OZONE RESISTANCE ON COMPLETE CABLE		
9.1	Method A: Temperature 25 ± 2°C Duration 24 h Ozone concentration (by volume) (250-300)*10E-4 %		P <input type="checkbox"/> F <input type="checkbox"/> N/A <input checked="" type="checkbox"/> N/T <input type="checkbox"/>
9.2	Method B: Temperature 40 ± 2°C Relative humidity 55 ± 5 % Duration 72 h Ozone concentration (by volume) (150-250)*10E-6 %		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
9.3	After the test no cracks are visible	no visible crack	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
10	WEATHERING / UV RESISTANCE TEST (see annex E)		
10.1	Temperature during drying 65± 3 °C Relative humidity 65 % Power at wavelength betw. 300 to 400 nm 60 ± 2 W/m² Duration spraying/ drying 18 / 102 Min Duration 720 h After test conditioning the exposed five specimens at ambient temperature for 16h		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 11 von 21
Page 11 of 21

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation
10.2	Variation of tensile strength \geq 70% Variation of elongation at break \geq 70% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
11	DYNAMIC PENETRATION TEST (annex D) <i>see table 7.4</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
12	DAMP HEAT TEST		
12.1	Temperature 90 °C Duration 1000 h Relative humidity min. 85 % Reconditioning period 16 to 24 h		
12.2	Variation of tensile strength max. - 30% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	Variation of elongation at break max. - 30% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
13	SHRINKAGE		
13.1	Length of cable before test [mm] Length of cable after test: [mm]	1X2,5: 300; 1X6: 299 1X2,5: 300; 1X6: 298	
13.2	Shrinkage after test max 2%: [%]	1X2,5: 0,3 1X6: 1	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
14	TEST UNDER FIRE CONDITIONS		
14.1	Length of sample 600 \pm 25 mm Temperature during conditioning 23 \pm 5 °C Relative humidity during conditioning 50 \pm 20 % Duration of conditioning 16 h Overall diameter of test sample: [mm] Duration of flame application, depending on the diameter of the test sample 60 s	overall diameter: 1X2,5: 5,52mm 1X6: 6,92mm	
	Distance from the lower edge of the top support to the upper onset of charring > 50 mm: [mm]	1X2,5: 420mm 1X6: 380mm	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 12 von 21
Page 12 of 21

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation
	Charring does not extend downwards to a point greater than 540 mm from the lower edge of the top support: [mm]	1X2.5: 495mm 1X6: 475mm	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
15	SMOKE EMISSION OF COMPLETE CABLE ACCORDING TO EN 61034-2		
15.1	Test result light transmittance, min 60%: [%]	1X2,5: 87 1X4: 97 1X6: 95	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
16	ASSESSMENT OF HALOGEN ACCORDING TO 50525-1 ANNEX B		
16.1	Determination of halogen		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	Chloride, fluoride and bromide have been determined during test acc. to annex C (If yes, continue with phase 1)		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	Phase 1		
	ph-value min. 4,3: [ph]	1X2,5: 5,9 for insulation 4,9 for sheath 1X6: 5,1 for insulation 6,3 for sheath	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	If ph-value min. 4,3 conductivity must be measured: [µS/mm]	1X2,5: 0,2 for insulation 0,4 for sheath 1X6: 0,4 for insulation 0,3 for sheath	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	If conductivity is > 2,5 µS/mm but < 10 µS/mm continue with phase 2, if conductivity is max. 2,5 µS/mm material is acceptable without phase 2		P <input type="checkbox"/> F <input type="checkbox"/> N/A <input checked="" type="checkbox"/> N/T <input type="checkbox"/>
	Phase 2		
	Chlorine- and bromine content max. 0,5% (continue with phase 3): [%]	1X2,5: =<0,5 for both insulation and sheath 1X6: =<0,5 for both insulation and sheath	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	Phase 3		

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 13 von 21
Page 13 of 21

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation
	Flouride content max. 0,5%: [%]	1X2,5: =<0,02 for both insulation and sheath 1X6: =<0,02 for both insulation and sheath	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
Table B.1	REQUIREMENTS FOR INSULATION AND SHEATHING MATERIALS		
1	MECHANICAL CHARACTERISTICS		
1.1	Mechanical properties before ageing		
1.1.1	Determined median values for tensile strength		
	- for insulation min. 8,0N/mm ² <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	- for sheath min. 8,0N/mm ² <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.1.2	Determined median values for elongation at break		
	- for insulation min. 125% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	- for sheath min 125% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.2	MECHANICAL PROPERTIES AFTER AGEING IN OVEN (150°C/168H)		
1.2.1	Test temperature: 150 ± 2°C Test duration: 168h		
1.2.2	Determined median values for tensile strength		
	- for insulation variation max. - 30% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 14 von 21
Page 14 of 21

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation
	- for sheath variation max. - 30% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.2.3	Determined median values for elongation at break		
1.2.3	- for insulation variation max. - 30% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	- for sheath variation max. - 30% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.3	HOT SET TEST IN OVEN ACCORDING TO EN 60811-507 (250°C / 15 MIN / 20N/cm2)		
1.3.2	Elongation under load max. 100%: [%]	H1Z2Z2-K 1X125: insulation: 35; sheath: 20 H1Z2Z2-K 1X6: insulation: 20; sheath: 55	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
	Permanent elongation after cooling max. 25%: [%]	H1Z2Z2-K 1X1,5: insulation: 0; sheath: 0 H1Z2Z2-K 1X6: insulation: 0; sheath: 0	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.4	THERMAL ENDURANCE TEST ACCORDING TO EN 60216 PARTS 1 AND 2		
	The determined Arrhenius curve resulting from the test results of test according to IEC 60216-2 shows a thermal endurance of min. 20.000h at a temperature of 120°C. <i>SEE ENCLOSURE ARRHENIUS-CALCULATION SHEET</i>	specimens obtained from the complete cable of H1Z2Z2-K 1X2,5	P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.5	COLD ELONGATION TEST ACCORDING TO EN 60811-505		
1.5.1	Test conditions see EN 60811-505		
1.5.2	Elongation of break min. 30%: [%]		P <input type="checkbox"/> F <input type="checkbox"/> N/A <input checked="" type="checkbox"/> N/T <input type="checkbox"/>
1.6	SHEATH RESISTANCE AGAINST ACID AND ALKALINE SOLUTION ACCORDING TO EN 60811-404		

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 15 von 21
Page 15 of 21

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation
1.6.1	Acid: N-Oxal-acid Alkaline solution: N-sodium hydroxide solution Temperature 23 C° Duration 168 h		
1.6.2	max. Variation of tensile strength ± 30% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.6.3	Min. Elongation at break > 100% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.7	COMPATIBILITY TEST ACCORDING TO EN 60811-401		
1.7.1	Test conditions: Temperature 135 ± 2°C Duration of treatment 168 h		
1.7.2	Variation of tensile strength insulation max. ± 30% Variation of tensile strength sheath max. - 30% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>
1.7.3	Variation of elongation at break insulation max. ± 30% Variation of elongation at break sheath max. - 30% <i>SEE TABLE B.1</i>		P <input checked="" type="checkbox"/> F <input type="checkbox"/> N/A <input type="checkbox"/> N/T <input type="checkbox"/>

Prüfbericht-Nr.: 50163017 001
Test Report No.:

Seite 16 von 21
Page 16 of 21

Absatz	EN 50618:2014	Messergebnisse - Bemerkungen	Bewertung
Clause	Anforderungen - Prüfungen / Requirements - Tests	Measuring results - Remarks	Evaluation

		blank page	
--	--	------------	--

ANLAGE zum Prüfbericht-Nr.: 50163017 001
APPENDIX to Test Report No.:

Seite 17 von 21
Page 17 of 21

ZUSATZ-DOKUMENTATION
ADDITIONAL DOCUMENTATION

H1Z2Z2-K 1X2,5 mm²

Table B.1 MECHANICAL CHARACTERISTICS

Samples of insulation	<input type="checkbox"/> test plate	<input checked="" type="checkbox"/> sleeve probe	black	
Samples of sheath	<input checked="" type="checkbox"/> test plate	<input type="checkbox"/> sleeve probe	black	
INSULATION				
	Values of tensile strength [N/mm ²]:			
Before ageing	-	-	-	12,9
After ageing in oven	-	-	-	14,1
After damp heat test	-	-	-	-
After test of mutual influence	-	-	-	13,4
	Values of elongation at break [%]:			
Before ageing	400	400	400	400
After ageing in oven	410	400	400	400
After damp heat test	-	-	-	-
After test of mutual influence	400	400	400	400
During cold elongation test	-	-	-	-
SHEATH				
	Values of tensile strength [N/mm ²]:			
Before ageing	13,1	12,9	12,5	12,8
After ageing in oven	13,1	12,6	13,5	13,3
After damp heat test	12,8	12,5	12,1	13,8
After storing in acid	9,3	10,1	11,4	12,2
After storing in alkaline	11,1	11,9	10,7	12,3
After storing UV Weathering	12,9	13,1	12,7	12,8
After test of mutual influence	14,6	13,6	16,4	14,9
	Values of elongation at break [%]:			
Before ageing	220	240	220	200
After ageing in oven	200	200	200	220
After damp heat test	260	240	240	200
After storing in acid	240	220	260	260
After storing in alkaline	240	240	240	220
After storing UV Weathering	30	30	30	30
After test of mutual influence	220	220	200	200
During cold elongation test	-	-	-	-

ANLAGE zum Prüfbericht-Nr.: 50163017 001
APPENDIX to Test Report No.:

Seite 18 von 21
Page 18 of 21

ZUSATZ-DOKUMENTATION
ADDITIONAL DOCUMENTATION

H1Z2Z2-K 1X6mm²

Table B.1 MECHANICAL CHARACTERISTICS

Samples of insulation	<input type="checkbox"/> test plate	<input checked="" type="checkbox"/> sleeve probe	black	
Samples of sheath	<input checked="" type="checkbox"/> test plate	<input type="checkbox"/> sleeve probe	black	

INSULATION

	Values of tensile strength [N/mm ²]:					Median [N/mm ²]	Variation [%]
	-	-	-	-	-	17,3	-
Before ageing	-	-	-	-	-	17,3	-
After ageing in oven	-	-	-	-	-	19,1	+10
After damp heat test	-	-	-	-	-	-	-
After test of mutual influence	-	-	-	-	-	18,5	+7
Values of elongation at break [%]:						Median %	Variation %
Before ageing	230	210	220	220	220	220	-
After ageing in oven	220	220	230	220	210	220	0
After damp heat test	-	-	-	-	-	-	-
After test of mutual influence	220	200	220	210	220	220	0
During cold elongation test	-	-	-	-	-	-	-

SHEATH

	Values of tensile strength [N/mm ²]:					Median [N/mm ²]	Variation [%]
	15,6	15,6	15,7	13,6	15,6	15,6	-
Before ageing	15,6	15,6	15,7	13,6	15,6	15,6	-
After ageing in oven	15,9	15,4	15,2	16,3	14,8	15,4	-1
After damp heat test	15,4	14,8	15,3	15,2	13,3	15,2	-3
After storing in acid	13,9	11,2	14,3	13,9	13,7	13,9	-11
After storing in alkaline	12,7	16,5	14,5	12,4	14,2	14,2	-9
After storing UV Weathering	15,2	12,9	13,2	14,6	16,3	14,6	94
After test of mutual influence	15,2	16,3	17,9	18,4	17,6	17,6	+13
Values of elongation at break [%]:						Median [%]	Variation [%]
Before ageing	150	160	180	160	180	160	-
After ageing in oven	150	15,4	15,2	16,3	14,8	15,4	-6
After damp heat test	150	130	150	180	160	150	-6
After storing in acid	200	210	210	200	200	200	+25
After storing in alkaline	180	180	180	160	170	180	+13
After storing UV Weathering	150	150	150	150	170	150	94
After test of mutual influence	150	150	160	150	160	150	-6
During cold elongation test	-	-	-	-	-	-	-

ANLAGE zum Prüfbericht-Nr.: 50163017 001
APPENDIX to Test Report No.:

Seite 19 von 21
Page 19 of 21

ZUSATZ-DOKUMENTATION
ADDITIONAL DOCUMENTATION

Table 5.1.5 COMPLIANCE OF CONDUCTOR WITH CLASS 5 OF IEC 60228

	Diameter of single wires		Resistance of conductor	
	Max. [mm]	Measured [mm]	Max. [Ω /km]	Measured [Ω/km]
H1Z2Z2-K 1X2,5mm ²	0,26	0,24	8,21	7,32
H1Z2Z2-K 1X6mm ²	0,31	0,29	3,39	2,96

Table 8.1 INSULATION RESISTANCE VALUE

Cross section	Insulation resistance at 20°C		Insulation resistance at 90°C	
	Min. MΩ /km	Measured MΩ /km	Min. MΩ /km	Measured MΩ /km
2,5	690	1270	0,69	0,75
6	500	2470	0,50	1,64

Table 5.2.3 WALL THICKNESS OF INSULATION

Values of measured wall thickness not less than stated in clause 5.2.3 of this standard (smallest value shall be highlighted) [mm]							Average value [mm]	Minimum thickness of insulation [mm]	Smallest measured value not less than $t_m \geq 0,9t_s - 0,1$ mm
1X2,5mm ²	-	-	-	-	-	-	0,9	0,80	0,53
1X6mm ²	-	-	-	-	-	-	1,1	0,98	0,53

Table 5.3.3 WALL THICKNESS OF SHEATH

Values of measured wall thickness not less than stated in clause 5.3.3 of this standard (smallest value shall be highlighted) [mm]							Average value [mm]	Minimum thickness of sheath [mm]	Smallest measured value not less than $t_m \geq 0,85t_s - 0,1$ mm
1X2,5mm ²	-	-	-	-	-	-	1,0	0,88	0,58
1X6mm ²	-	-	-	-	-	-	0,9	0,79	0,58

ANLAGE zum Prüfbericht-Nr.: 50163017 001
APPENDIX to Test Report No.:

Seite 20 von 21
Page 20 of 21

ZUSATZ-DOKUMENTATION
ADDITIONAL DOCUMENTATION

Table 7.3.3 MEAN VALUES AND OVALITY OF CABLE

Values of measured ovality not less than stated in clause 7.3.3 of this standard

	Sample 1		Sample 2		Sample 3		Average value [mm]	Manufacturer spec. [mm]	Ovality [%]
	Value 1 [mm]	Value 2 [mm]	Value 1 [mm]	Value 2 [mm]	Value 1 [mm]	Value 2 [mm]			
1X2,5mm ²	5,736	5,558	5,663	5,543	5,673	5,602	5,6	-	3
1X6mm ²	-	-	-	-	-	-	7,4	-	1

Table 7.4 Dynamic penetration test (Annex D)

Nominal cross-sectional area of conductor: [mm ²]	2,5	6					
Rated diameter of conductor according to table 2 of IEC 60719 (D _n): [mm]	1,95	3,0					
Minimum value of force (150 * √D _n): [N]	209	260					
Determined mean value of force: [N]	284	374					

1.4 Thermal endurance properties

Testing method according to EN 60216-2

Test conditions

- Temperature Index : 120
 Selected exposure temperatures : 185°C, 165°C, 145°C
 Elongation at break : 50 %

Test sample	Time to end-point at exposure temperature 185°C hour	Specified time (min.) h	Time to end-point at exposure temperature 165°C hour	Time to end-point at exposure temperature 145°C hour	Specified time (min.) h	Obtained absolute temperature K	Absolute temperature (min.) K
insulation	110	100	817	6624	5000	409	393
sheath	106	100	709	6445	5000	408	393

ANLAGE zum Prüfbericht-Nr.: 50163017 001
APPENDIX to Test Report No.:

Seite 21 von 21
Page 21 of 21

ZUSATZ-DOKUMENTATION
ADDITIONAL DOCUMENTATION

Thermal endurance graph for insulation material




Figure 1 Arrhenius curve of Insulation

Remark: The value of t is equal to 20,000 h at $\lg(t)=4,30$, so $Tl=136^{\circ}\text{C}$

Thermal endurance graph for sheath material




Figure 2 Arrhenius curve of Sheath

Remark: The value of t is equal to 20,000 h at $\lg(t)=4,30$, so $Tl=135^{\circ}\text{C}$

End of test report

Measurement and Test Equipment List

Attachment:

Report No.: 50163017 001

Order No.: 1140035154

National Quality Supervision and Testing Center for Cables and Wires (Jiangsu)

500 Lvyuan Road, Yixing, China

Description	MTE Type/model Internal ID	Next Calibration Date
Digital micrometer	QF-7	2017-07-10
Steel rule	GZ-26	2018-03-22
Vernier caliper	KC-2	2018-05-26
Thickness gauge	DL-17	2017-12-01
Thickness gauge	DL-51	2018-05-27
Thickness gauge	DL-53	2018-04-27
Steel rule	GZ-15	2017-10-16
WCDMS cable and wire construction measurement system	Y3-2106-4140	2018-06-05
QJ57P D.C.bridge	Y2-1174-2116	2017-10-13
High insulation resistance meter	Y3-1344-2536	2017-07-17
Voltage/Insulation tester	Y3-1343-2535	2017-12-29
Thermostatic bath device	Y3-1224-2270	2017-08-28
Voltage/Insulation tester	Y3-2257-4358	2018-04-20
Thermostatic bath device	Y3-2320-4421	2018-01-02
Computer-controlled electronic tensile tester	Y3-2310-4411	2018-06-11
Computer-controlled electronic tensile tester	Y3-1830-3573	2017-12-19
Heat ageing test chamber	Y3-2272-4373	2018-05-08
Heat ageing test chamber	Y3-2275-4376	2018-05-09
Heat ageing test chamber	Y3-2278-4379	2018-05-08
Heat ageing test chamber	Y3-2270-4371	2018-05-08

Measurement and Test Equipment List

Heat ageing test chamber	Y3-2268-4369	2018-05-08
Heat ageing test chamber	Y3-2271-4372	2018-05-08
Heat ageing test chamber	Y3-1425-2723	2018-07-23
Xeon lamp weather resistance test chamber	Y3-2255-4356	2018-04-20
Low temperature bending tester	Y3-1392-2595	2017-12-29
Low temperature test chamber	Y3-945-1659	2018-06-05
Heat ageing test chamber	Y3-1182-2124	2018-05-08
Hot set tester	Y3-709-1142	2018-01-02
Heat ageing test chamber	Y3-2277-4378	2018-05-08
Heat ageing test chamber	Y3-2269-4370	2018-05-08
Heat ageing test chamber	Y3-2273-4374	2018-05-08
Computer-controlled electronic tensile tester	Y3-1557-2999	2018-11-30
Heat ageing test chamber	Y3-1209-2220	2018-05-08
Multiple ion measuring instrument	Y3-1583-2915	2018-04-26
Electronic analytical balance	Y3-1339-2531	2017-11-29
Corrosion resistance tester	Y3-1861-3626	2017-08-04
Corrosion resistance tester	Y3-2296-4397	2018-06-11
Acidity meter	Y3-2224-4325	2017-12-14
Conductivity meter	Y3-2225-4326	2017-12-14
Low temperature test chamber	Y3-643-1049	2018-03-30
Low temperature impact tester	Y3-272-447	2018-05-26
Vertical fire tester	Y3-2132-4182	2017-12-29
Ozone ageing oven	Y3-2131-4181	2017-11-15
Smoke density tester	Y3-1859-3623	2017-06-29
Following blank		



Date and Signature: _____